

ATES Smart Grids research project overview and first results

Bloemendal, Martin; Jaxa-Rozen, Marc; Rostampour Samarin, Vahab; Konadu, Daniel Dennis

Publication date

2016

Document Version

Final published version

Published in

Geophysical Research Abstracts (online)

Citation (APA)

Bloemendal, M., Jaxa-Rozen, M., Rostampour Samarin, V., & Konadu, D. D. (2016). ATES Smart Grids research project overview and first results. *Geophysical Research Abstracts (online)*, 18, 1-1. [EGU2016-2979].

Important note

To cite this publication, please use the final published version (if applicable). Please check the document version above.

Copyright

Other than for strictly personal use, it is not permitted to download, forward or distribute the text or part of it, without the consent of the author(s) and/or copyright holder(s), unless the work is under an open content license such as Creative Commons.

Takedown policy

Please contact us and provide details if you believe this document breaches copyrights. We will remove access to the work immediately and investigate your claim.

ATES Smart Grids research project overview and first results

Martin Bloemendal (1,2), Marc Jaxa-Rozen (1), and Vahab Rostampour (1)

(1) Delft University of Technology, Delft, Netherlands (j.m.bloemendal@tudelft.nl), (2) KWR Watercycle research institute

Background: ATES application is growing

Application of seasonal Aquifer Thermal Energy Storage (ATES) contributes to energy saving and Greenhouse Gas (GHG)-reduction goals (CBS, 2015; EU, 2010, 2014). Recently it was shown that ATES is applicable in several parts of the world (Bloemendal et al., 2015). While in most parts of the world adoption is just beginning, in the Netherlands progressive building energy efficiency regulation already caused the adoption of ATES to take off (Heekeren and Bakema, 2015; Sommer et al., 2015). As a result of the large number of ATES systems in the Netherlands, the subsurface plays a crucial role in the energy saving objectives of The Netherlands (Kamp, 2015; SER, 2013).

Problem: suboptimal use of the subsurface for energy storage

ATES systems accumulate in urban areas, as can be expected with a large growth of ATES systems; at many locations in Dutch cities demand for ATES transcends the available space in the subsurface (Li, 2014; Sommer et al., 2015). Within in the Dutch legal framework and state of technology optimal use of the subsurface is not secured; i.e. minimizing the total GHG emissions in a certain area. (Bloemendal et al., 2014; Li, 2014). The most important aspects in this problem are A) the permanent and often unused claim resulting from static permits and B) excessive safety zones around wells to prevent interaction. Both aspects result in an artificial reduction of subsurface space for potential new ATES systems. Recent research has shown that ground energy storage systems could be placed much closer to each other (Bakr et al., 2013; Sommer et al., 2015), and a controlled/limited degree of interaction between them can actually benefit the overall energy savings of an entire area.

Solution: the approach and first results of our research project on ATES Smart Grids

The heating and cooling demand of buildings is a dynamic and hard to predict process, due to effects such as weather, climate change, changing function and usage of buildings over time. This naturally also applies to the required storage capacity in the subsurface. Because of these uncertainties the only way to optimally use the subsurface is to shift the organization of the subsurface space use from the planning phase to the operational phase.

Our solution therefore provides a framework in which adaptability plays a key role. Optimal use can only be achieved when users have insight in the status and their effect on the resource they are exploiting (Ostrom, 1990). Therefore exchange of information is necessary for individual users to adapt their operation based on the current state of the subsurface and their energy demand via a controller and compensation measures.

To arrive at a proof-of-concept based on our approach, we use expertise and models from different fields such as administrative policy and decision making, systems and control, and hydrogeology. A central element is the so-called agent-based model (ABM), which is a technique widely used in administrative policy and decision making in order to simulate the behavior of actors. Each agent has a controller that determines how the geothermal energy system must satisfy the energy demand of the building. Thus properties and characteristics of the building and the system are included in this controller. We apply a so-called Model Predictive Control (MPC) approach, which means that the controller takes into account the expected energy demand in the future, and also how its control strategy influences the performance of its own resources. The computed control action is implemented on a groundwater model of the area including all geothermal energy systems, which then serves as the basis for planning the control actions over the next period.

This concept is developed in 3 steps up to the scale of a typical Dutch town. Currently we have a proof-of-concept based on a fictitious academic model (1), which we are currently scaling up to the city-center area of Utrecht (2) after which we then incorporate the entire city of Amsterdam (3). The first results of the academic model are promising (Jaxa-Rozen et al., 2015), it shows that stable situations result even for ATES system that are placed a lot closer together than what current regulations would dictate. This has a positive effect on the total

GHG emission reduction, but a negative effect on individual efficiency.

In the presentation at EGU we will show results from the academic case, discuss several challenges for the optimization and present details on the analytical geohydrological ATEs well model required for the controller to keep track of energy losses in its own wells.

References

- Bakr, M., van Oostrom, N., Sommer, W., 2013. Efficiency of and interference among multiple Aquifer Thermal Energy Storage systems; A Dutch case study. *Renewable Energy* 60, 53-62.
- Bloemendal, M., Olsthoorn, T., Boons, F., 2014. How to achieve optimal and sustainable use of the subsurface for Aquifer Thermal Energy Storage. *Energy Policy* 66, 104-114.
- Bloemendal, M., Olsthoorn, T., van de Ven, F., 2015. Combining climatic and geo-hydrological preconditions as a method to determine world potential for aquifer thermal energy storage. *Science of the Total Environment* 538 621-633.
- CBS, 2015. *Hernieuwbare energie in Nederland 2014 (renewable energy in NL)*. Central authority for statistics in NL, Den Haag.
- EU, 2010. Directive on the energy performance of buildings, in: Union, O.J.o.t.E. (Ed.), 153;13-35. EU-Parliament, European Union, Strasbourg.
- EU, 2014. A review of factors affecting environmental and economic life-cycle performance for electrically-driven heat pumps, in: Commission, E. (Ed.).
- Heekeren, V.v., Bakema, G., 2015. The Netherlands Country Update on Geothermal Energy, World Geothermal Congress, Melbourne.
- Jaxa-Rozen, M., Kwakkel, J.H., Bloemendal, M., 2015. The Adoption and Diffusion of Common-Pool Resource-Dependent Technologies: The Case of Aquifer Thermal Energy Storage Systems, PICMET, Portland.
- Kamp, H., 2015. *Warmtevisie*, ministry of economic affairs, Den Haag.
- Li, Q., 2014. Optimal use of the subsurface for ATEs systems in busy areas, *Hydrology*. Delft University of Technology, 2014.
- Ostrom, E., 1990. *Governing the Commons*. Cambridge University Press, Cambridge.
- SER, 2013. *Energie Akkoord*. Social economical council.
- Sommer, W., Valstar, J., Leusbrock, I., Grotenhuis, T., Rijnaarts, H., 2015. Optimization and spatial pattern of large-scale aquifer thermal energy storage. *Applied Energy* 137, 322-337.