

CO2 monitoring to assess ventilation rate: practical suggestions from a laboratory study

Zhang, D.; Ding, Er; Bluysen, P.M.

DOI

[10.34641/clima.2022.93](https://doi.org/10.34641/clima.2022.93)

Publication date

2022

Document Version

Final published version

Published in

CLIMA 2022 The 14th REHVA HVAC World Congress

Citation (APA)

Zhang, D., Ding, E., & Bluysen, P. M. (2022). CO2 monitoring to assess ventilation rate: practical suggestions from a laboratory study. In *CLIMA 2022 The 14th REHVA HVAC World Congress* Article 1531 TU Delft OPEN Publishing. <https://doi.org/10.34641/clima.2022.93>

Important note

To cite this publication, please use the final published version (if applicable).
Please check the document version above.

Copyright

Other than for strictly personal use, it is not permitted to download, forward or distribute the text or part of it, without the consent of the author(s) and/or copyright holder(s), unless the work is under an open content license such as Creative Commons.

Takedown policy

Please contact us and provide details if you believe this document breaches copyrights.
We will remove access to the work immediately and investigate your claim.

CO₂ monitoring to assess ventilation rate: practical suggestions from a laboratory study

Dadi Zhang ^a, Er Ding ^a, Philomena M. Bluysen ^a

^a Chair Indoor Environment, Faculty of Architecture and the Built Environment, Delft University of Technology, the Netherlands, {D.Zhang-2, E.Ding, P.M.Bluysen}@tudelft.nl

Abstract. Several recent studies have demonstrated that ventilation plays an important role in the transmission of SARS-CoV-2 (the coronavirus that causes COVID-19) in public buildings, such as schools. However, there are no clear rules on how to assess the ventilation performance in classrooms, especially during a pandemic. Therefore, the main objective of this study was to develop guidance to assess the ventilation performance under different ventilation regimes. A full-scale laboratory study was conducted in the Experience room of the SenseLab, where CO₂ concentrations were monitored at 19 locations (18 indoors and one outdoors) simultaneously and recorded every 30 seconds by HOB0® CO₂ loggers. The experiment was conducted under four different ventilation regimes: ‘600 m³/h mixing’, ‘open windows’, ‘no ventilation’, and ‘open windows and door’. Each regime lasted 50 minutes, which is approximately the duration of one normal lesson at Dutch secondary schools. Six (three males and three females) healthy subjects were invited to participate in this experiment as CO₂ sources. Results showed that CO₂ concentrations varied significantly between different measurement locations in the same classroom, especially under natural ventilation conditions. This demonstrates the need of monitoring the CO₂ concentration, next to outdoors, at more than one location in a classroom. The finding of this study could contribute to a standardized way of monitoring CO₂ concentrations and the assessment of ventilation performance of an occupied space.

Keywords. CO₂ concentration, ventilation regimes, classrooms, monitoring guidance.

DOI: <https://doi.org/10.34641/clima.2022.93>

1. Introduction

After being proved and confirmed by many scientists, the airborne transmission of SARS-CoV-2 transmission has finally been accepted as the dominant transmission route by the whole world [1-3]. Along with that, people have begun to raise concerns over the indoor air quality (IAQ) and ventilation [4, 5]. Increasing ventilation has been listed as one of the main measures against the spread of SARS-CoV-2 by many governments. However, how do we know whether the ventilation is enough or how to assess the ventilation efficiency? According to previous studies, CO₂ concentration has usually been taken into account as the indicator of the amount of ventilation or for IAQ [6-8]. Because CO₂ measurement devices are easily usable, relatively cheap, and reasonable accurate, CO₂ is widely used to estimate ventilation rate in spaces [8, 9], and the history of using CO₂ as an indicator of the ventilation performance can be traced back to more than 160 years ago [10]. Besides, several studies suggested CO₂ can be seen as the proxy of COVID-19 infection

risk [7, 11-13]. because both infected aerosols and CO₂ are mainly originating from human exhalation. For example, by using monitored CO₂ concentrations, Burridge et al. [12] established a predictive and retrospective model to estimate the risk of airborne infection in regularly occupied spaces, such as office or school classrooms.

However, despite the widely use of CO₂-based methods, there is no consistent guidance for CO₂ monitoring. The selection of measurement locations of and number of sensors mainly depends on researchers’ personal experiences, and therefore varied a lot among previous studies [14-16]. For example, in some studies the CO₂ concentration was measured at only one indoor location per room [17, 18], while others conducted the measurement at three or four locations to get more accurate ventilation rates [19, 20]. Additionally, the height of measurement point was also not consistent. In studies conducted by Mumovic et al. [21], Clements-Croome et al. [22], and Turanjanin et al. [23], the sensors/devices were placed at the height of 1.1m

above the floor, while the height was set to 1.2m in studies conducted by Hou et al. [17] and Krawczyk et al. [24].

According to the lab study carried out by Mahyuddin et al. [25], CO₂ was not distributed homogeneously in the investigated classrooms, therefore, monitoring CO₂ at only one location might lead to inaccurate result, and the selection of monitoring location should depend on the ventilation regimes. To accurately assess the ventilation rate in an occupied space, a unified and detailed CO₂ monitoring protocol including different strategies that are applicable for different ventilation regimes is needed. Therefore, in this study a full-scale experiment with multiple measurement locations in the SenseLab [26] was conducted to better understand the CO₂ distribution in a room under different ventilation regimes, and developed a consistent CO₂ monitoring guidance, based on the results.

2. Methods

2.1 study design


The full-scale experiment was conducted in the Experience room (6.5 (l) × 4.2 (b) × 2.6 (h)) of the SenseLab [26] (See Fig. 1). Six healthy subjects, including three males and three females, volunteered to participate in this experiment. They were asked to remove their masks after seated [27]. The average age of them was 27 ± 2 years old. Prior to the study, all subjects gave informed consent to participate in the experiment, and they were able to leave the Experience room at any time in the case they were not feeling comfortable.



Fig. 1 – Experimental setting.

19 measurement locations (18 indoors and one outdoors) were selected in this study. As shown in Fig. 2, six of them ('D_') were on top of six desks at 1.1m above the floor, two of them were in the centre ('C') / front ('F') of the room at 1.1m and 1.6m respectively, and the last eight of them were on the four walls ('W_'), also at 1.1m and 1.6 m. CO₂ concentrations at all these locations were measured every 30 seconds using HOB0® CO₂ loggers (which have an accuracy of ±50 ppm ±5% of reading in the

range of 0-5000 ppm).



Note: measurement locations at 1.1m were marked in red and at 1.6m were marked in green.

Fig.2 - Measurement locations in the experience room.

The same measurement was repeated four times under four different ventilation regimes: (1) mixing ventilation with a ventilation rate of 600 m³/h (in which air come from four 600 × 600 mm grills on the ceiling and exhaust from the perforated plinth on the short side of the room); (2) natural ventilation with windows open; (3) no ventilation; and (4) natural ventilation with both door and windows open. Each tested condition lasted 50 minutes. To reset the CO₂ concentration to the default level (close to the outdoor level), a ten-minute break (during which occupants left the room and the ventilation was set as 120m³/h mixing ventilation) was inserted between each of two test periods. According to the weather report, the outdoor condition on the experiment day was 16 °C, 63%, and with 13 km/h north wind [28].

2.2 Data analysis

All collected data was imported and analysed using SPSS version 26.0 (SPSS Inc. Chicago, IL, USA) in the following steps. First, the average CO₂ concentration of all the indoor locations were compared among the last ten measurements (i.e. the last five minutes) of each test periods using one-way ANOVA to check whether they reach a steady state. Second, the average (standard deviation) CO₂ concentration during the last five minutes of each period at each location was analysed with descriptive statistics. Third, CO₂ concentrations were compared between different ventilation regimes with one-way ANOVA. Then, the average CO₂ concentrations were compared among different horizontal locations at 1.1m and 1.6m, separately, using one-way ANOVA. Finally, using paired samples t-test, the difference of CO₂ concentrations between two heights was compared at five locations (four walls and the centre), separately.

3. Results and Discussion

3.1 CO₂ concentrations under different ventilation regimes

According to the results collected from this study, the trends in CO₂ variation over time at all indoor locations were similar. Take the centre location (1.1m) as an example, as shown in Fig. 3, when the ventilation regime was '600 m³/h mixing', the CO₂ concentration was relatively steady and low. During 'open windows' regime, the CO₂ concentration increased at the beginning but reached a relatively steady state at the end. When there was 'no ventilation', the CO₂ concentration increased significantly and continuously during the whole period. With the 'open door and windows', the CO₂ concentration was similar to concentration under the '600 m³/h mixing' condition, but with slightly more fluctuations. According to the one-way ANOVA test result, the CO₂ concentration varied significantly between these four ventilation regimes ($F(3, 676) = 8522, p < 0.001$). The Bonferroni test showed that there was a significant difference of CO₂ concentration between almost every two ventilation regimes, except for between '600 m³/h mixing' and 'open door and windows'. The CO₂ concentration during these two ventilation regimes were much lower than with the other two regimes. This indicated that natural ventilation, under certain conditions, could achieve a similar ventilation effect as mechanical ventilation.




Fig. 3 - CO₂ variation over time at one location.




Fig. 4 - CO₂ distribution in the Experience room.

Additionally, it can be seen from the figure that the CO₂ concentration could reach to a relatively steady state at the end of all test periods, except for the third period- 'no ventilation'; the CO₂ concentration hardly reached a plateau. Nevertheless, the results collected during the last five minutes seemed closest to the steady-state concentration. Besides, results of the one-way ANOVA test showed that the average CO₂ concentration collected from all indoor locations did not vary significantly among the last ten measurements (i.e. last five minutes) of all the periods, which indicated the CO₂ concentration during the last five minutes of all test periods could be considered as stable. Therefore, the following analyses were all based on the results collected during the last five minutes of each test period.

3.2 CO₂ distribution under different ventilation regimes

Fig. 4 illustrates the horizontal distribution of CO₂ concentrations at 1.1m and 1.6m in the Experience room under different ventilation regimes. The diameter of circles represents the difference of the average CO₂ concentration between each indoor measurement location and the outdoor location. Different colours of circles represent different ventilation regimes: red represents '600 m³/h mixing'; green represents 'open door and windows'; yellow represents 'open windows'; and blue represents 'no ventilation'. As shown in these figures, the CO₂ concentration was not evenly distributed in the Experience room. According to the one-way ANOVA test results (see the values mentioned below the subtitles), the CO₂ concentration did vary significantly between different locations ($p < 0.05$), especially under natural ventilation conditions (where higher F-values were found). Generally speaking, CO₂ concentrations measured on the wall were relatively higher than the other locations. Moreover, the lowest CO₂ concentration was always observed at location D_E, while the highest CO₂ concentration on the back wall (W_B), no matter under which ventilation regime.

Note: the numbers under the circles are the average (standard deviation) CO₂ concentrations measured at each location during the last five minutes.

To further identify the vertical distribution of CO₂ concentration, results collected from the locations with two different heights were compared with each other (1.1m vs. 1.6m). As shown in Table 1, in most cases, $t(9)$ was negative and the p value was less than 0.05, which means the CO₂ concentration was significantly higher at 1.6m than it at 1.1m, no matter under which ventilation regimes. This vertical distribution might be caused by the thermal plume produced by occupants. Given the fact that students spend most of their time sitting, instead of standing, the CO₂ concentration at 1.1m (the breathing height of a sitting person) should be paid more attention to in field studies.

Tab. 1 - Comparisons of CO₂ concentrations between two heights for different ventilation regimes.

Location	600 m ³ /h mixing	Open windows	No ventilation	Open windows and door
C	$t(9)=-12.3$ (< 0.001)	$t(9)= 5.2$ (0.001)	$t(9)= -8.8$ (< 0.001)	$t(9)= 2.1$ (0.065)
W_F	$t(9)=-23.7$ (< 0.001)	$t(9)=-20.9$ (< 0.001)	$t(9)=-14.0$ (< 0.001)	$t(9)=-32.3$ (< 0.001)
W_R	$t(9)=-6.9$ (< 0.001)	$t(9)=-5.8$ (< 0.001)	$t(9)=-5.2$ (0.001)	$t(9)=-16.3$ (< 0.001)
W_B	$t(9)=-8.3$ (< 0.001)	$t(9)=-7.1$ (< 0.001)	$t(9)=-6.8$ (< 0.001)	$t(9)=-6.4$ (0.004)
W_L	$t(9)=-3.6$ (0.006)	$t(9)=-7.0$ (< 0.001)	$t(9)= 2.8$ (0.021)	$t(9)=-3.3$ (0.010)

Note: all results were obtained from independent t -tests; p -values are shown in parentheses; results in bold means statistically significant difference ($p < 0.05$).

3.3 Proposed CO₂ monitoring guidance

According to the above-mentioned results, the CO₂ concentration was not well mixed, neither horizontally nor vertically, in the Experience room. Therefore, results collected from one measurement location might be inaccurate. However, in occupied classrooms, it is also infeasible to monitor CO₂ concentration at too many locations as this current study did. Thus, if the condition permits, according to the worst-case design principle [29], priorities are suggested to be given to the locations on walls since higher CO₂ concentrations were always measured on walls. If the CO₂ concentration on the wall could meet the requirement, so could the CO₂ concentration in the whole classroom. Moreover, the risk of equipment damage by students was relatively lower on walls than other locations, and in that case, locations on the front wall and back wall were recommended since they are usually farthest from the students' activity zone.

Additionally, to get an accurate result, the outdoor CO₂ concentration should also be monitored, and the number of occupants, open windows and open doors should be recorded during the monitoring period since all this information could cause a remarkable

difference in CO₂ concentrations/ventilation rates in classrooms.

4. Conclusions

To understand the CO₂ distribution in a classroom setting, CO₂ concentrations were measured at 18 indoor (and one outdoor) locations simultaneously in the Experience room of the SenseLab, under four different ventilation regimes. Based on the measurement results, this study concluded that only one measurement location might lead to inaccurate results, especially under natural ventilation regimes. Therefore, for future field studies, to get a better understanding of the ventilation/IAQ in classrooms, at least two CO₂ measurement locations on walls (especially the front and the back wall) at 1.1m should be selected in natural ventilated classrooms, while in mechanical ventilated classrooms (with both supply and exhaust), one measurement point seems enough because CO₂ is relatively well-mixed under this ventilation regime. In addition, outdoor CO₂ concentration was also suggested to be monitored, and the number and behaviour of occupants during the measurement should be recorded.

5. Remark

More detailed results and discussion of this study were published in the journal 'Indoor and Built Environment' [30].

6. Acknowledgement

This study is part of the ZonMw funded project "SARS-CoV-2 transmission in secondary schools and the influence of indoor environmental conditions" (no. 50-56300-98-689) coordinated by the University Medical Centre Utrecht in the Netherlands. Participants are the Erasmus Medical Centre in Rotterdam, the University of Utrecht, and the Delft University of Technology in Delft, all in the Netherlands.

7. References

- [1] Greenhalgh, T., J.L. Jimenez, K.A. Prather, Z. Tufekci, D. Fisman, and R. Schooley, *Ten scientific reasons in support of airborne transmission of SARS-CoV-2*. The lancet, 2021. **397**(10285): p. 1603-1605.
- [2] Dancer, S.J., P.M. Bluyssen, Y. Li, and J.W. Tang, *Why don't we just open the windows?* 2021, British Medical Journal Publishing Group.
- [3] Zhang, R., Y. Li, A.L. Zhang, Y. Wang, and M.J. Molina, *Identifying airborne transmission as the dominant route for the spread of COVID-19*. Proceedings of the

- National Academy of Sciences, 2020. **117**(26): p. 14857-14863.
- [4] Ding, E., D. Zhang, and P.M. Bluyssen, *Ventilation regimes of school classrooms against airborne transmission of infectious respiratory droplets: A review*. Building and Environment, 2022. **207**: p. 108484.
- [5] Sun, C. and Z. Zhai, *The efficacy of social distance and ventilation effectiveness in preventing COVID-19 transmission*. Sustainable cities and society, 2020. **62**: p. 102390.
- [6] Chatzidiakou, L., D. Mumovic, and A. Summerfield, *Is CO₂ a good proxy for indoor air quality in classrooms? Part 1: The interrelationships between thermal conditions, CO₂ levels, ventilation rates and selected indoor pollutants*. Building Services Engineering Research and Technology, 2015. **36**(2): p. 129-161.
- [7] Bartyzel, J., D. Zięba, J. Nęcki, and M. Zimnoch, *Assessment of Ventilation Efficiency in School Classrooms Based on Indoor-Outdoor Particulate Matter and Carbon Dioxide Measurements*. Sustainability, 2020. **12**(14): p. 5600.
- [8] Batterman, S., *Review and extension of CO₂-based methods to determine ventilation rates with application to school classrooms*. International journal of environmental research and public health, 2017. **14**(2): p. 145.
- [9] Kabirikopaei, A. and J. Lau, *Uncertainty analysis of various CO₂-Based tracer-gas methods for estimating seasonal ventilation rates in classrooms with different mechanical systems*. Building and Environment, 2020. **179**: p. 107003.
- [10] Olsson, D. *History of ventilation: Carbon dioxide as an indicator of indoor air pollution in 1858!* 2015 [cited 2021 30 May]; Available from: <https://www.swegonairacademy.com/2015/12/30/history-of-ventilation-carbon-dioxide-as-an-indicator-of-indoor-air-pollution-in-1858/>.
- [11] Peng, Z. and J.L. Jimenez, *Exhaled CO₂ as a COVID-19 infection risk proxy for different indoor environments and activities*. Environmental Science & Technology Letters, 2021. **8**(5): p. 392-397.
- [12] Burridge, H.C., S. Fan, R.L. Jones, C.J. Noakes, and P. Linden, *Predictive and retrospective modelling of airborne infection risk using monitored carbon dioxide*. arXiv preprint arXiv, 2020.
- [13] Hartmann, A. and M. Kriegel, *Risk assessment of aerosols loaded with virus based on CO₂-concentration*. Technical University of Berlin, Hermann-Rietschel-Institute, 2020.
- [14] Shaughnessy, R.J., U. Haverinen-Shaughnessy, A. Nevalainen, and D. Moschandreas, *A preliminary study on the association between ventilation rates in classrooms and student performance*. Indoor Air, 2006. **16**(6): p. 465-468.
- [15] Haverinen-Shaughnessy, U., D. Moschandreas, and R. Shaughnessy, *Association between substandard classroom ventilation rates and students' academic achievement*. Indoor Air, 2011. **21**(2): p. 121-131.
- [16] Toftum, J., B.U. Kjeldsen, P. Wargocki, H.R. Menå, E.M. Hansen, and G. Clausen, *Association between classroom ventilation mode and learning outcome in Danish schools*. Building and Environment, 2015. **92**: p. 494-503.
- [17] Hou, Y., J. Liu, and J. Li, *Investigation of indoor air quality in primary school classrooms*. Procedia Engineering, 2015. **121**: p. 830-837.
- [18] Schibuola, L., M. Scarpa, and C. Tambani, *Natural ventilation level assessment in a school building by CO₂ concentration measures*. Energy Procedia, 2016. **101**: p. 257-264.
- [19] Wargocki, P. and D.P. Wyon, *The effects of moderately raised classroom temperatures and classroom ventilation rate on the performance of schoolwork by children (RP-1257)*. Hvac&R Research, 2007. **13**(2): p. 193-220.
- [20] Wargocki, P., *Improving indoor air quality improves the performance of office work and school work*. Energy Systems Laboratory (<http://esl.tamu.edu>), 2008.
- [21] Mumovic, D., J. Palmer, M. Davies, M. Orme, I. Ridley, T. Oreszczyn, C. Judd, R. Critchlow, H. Medina, and G. Pilmoor, *Winter indoor air quality, thermal comfort and acoustic performance of newly built secondary schools in England*. Building and Environment, 2009. **44**(7): p. 1466-1477.
- [22] Clements-Croome, D.J., H. Awbi, Z. Bakó-Biró, N. Kochhar, and M. Williams, *Ventilation rates in schools*. Building and Environment, 2008. **43**(3): p. 362-367.
- [23] Turanjanin, V., B. Vučićević, M. Jovanović, N. Mirkov, and I. Lazović, *Indoor CO₂ measurements in Serbian schools and ventilation rate calculation*. Energy, 2014. **77**: p. 290-296.
- [24] Krawczyk, D., A. Rodero, K. Gładyszewska-Fiedoruk, and A. Gajewski, *CO₂ concentration in naturally ventilated classrooms located in different climates—Measurements and simulations*. Energy and Buildings, 2016. **129**: p. 491-498.
- [25] Mahyuddin, N., H.B. Awbi, and M. Alshitawi, *The spatial distribution of carbon dioxide in rooms with particular application to classrooms*. Indoor and Built

- Environment, 2014. **23**(3): p. 433-448.
- [26] Bluysen, P.M., F. van Zeist, S. Kurvers, M. Tenpierik, S. Pont, B. Wolters, L. van Hulst, and D. Meertins, *The creation of SenseLab: a laboratory for testing and experiencing single and combinations of indoor environmental conditions*. Intelligent Buildings International, 2018. **10**(1): p. 5-18.
- [27] Government of the Netherlands. *Wearing of face masks strongly advised*. 2020 [cited 2021 21 June]; Available from: <https://www.government.nl/latest/news/2020/10/02/wearing-of-face-masks-strongly-advised>.
- [28] Time and data. *June 2021 Weather in Delft — Graph*. 2021 [cited 2022 March 17]; Available from: <https://www.timeanddate.com/weather/netherlands/delft/historic?month=6&year=2021>.
- [29] Rustem, B. and M. Howe, *Algorithms for worst-case design and applications to risk management*. 2009: Princeton University Press.
- [30] Zhang, D., E. Ding, and P.M. Bluysen, *Guidance to assess ventilation performance of a classroom based on CO2 monitoring*. Indoor and Built Environment, 2022.

Data Statement

The datasets generated during and/or analysed during the current study are not available because more analysis will be conducted based on these datasets but the authors will make every reasonable effort to publish them in near future.