

**Principles of Charge Estimation Methods Using High-Frequency Current Transformer Sensors in Partial Discharge Measurements (vol 20, 2520, 2020)**

**Rodrigo-mor et al. Principles of charge estimation methods using high-frequency current transformer sensors in partial discharge measurements. sensors 2020, 20, 2520**

Rodrigo-Mor, Armando; Muñoz, Fabio A.; Castro-Heredia, Luis Carlos

**DOI**

[10.3390/s21186010](https://doi.org/10.3390/s21186010)

**Publication date**

2021

**Document Version**

Final published version

**Published in**

Sensors

**Citation (APA)**

Rodrigo-Mor, A., Muñoz, F. A., & Castro-Heredia, L. C. (2021). Principles of Charge Estimation Methods Using High-Frequency Current Transformer Sensors in Partial Discharge Measurements (vol 20, 2520, 2020): Rodrigo-mor et al. Principles of charge estimation methods using high-frequency current transformer sensors in partial discharge measurements. sensors 2020, 20, 2520. *Sensors*, 21(18), [6010]. <https://doi.org/10.3390/s21186010>

**Important note**

To cite this publication, please use the final published version (if applicable). Please check the document version above.

**Copyright**

Other than for strictly personal use, it is not permitted to download, forward or distribute the text or part of it, without the consent of the author(s) and/or copyright holder(s), unless the work is under an open content license such as Creative Commons.

**Takedown policy**

Please contact us and provide details if you believe this document breaches copyrights. We will remove access to the work immediately and investigate your claim.

## Erratum

# Erratum: Rodrigo-Mor et al. Principles of Charge Estimation Methods Using High-Frequency Current Transformer Sensors in Partial Discharge Measurements. *Sensors* 2020, 20, 2520

Armando Rodrigo-Mor \*, Fabio A. Muñoz and Luis Carlos Castro-Heredia

Electrical Sustainable Energy Department, Delft University of Technology, 2628 CD Delft, The Netherlands; f.a.munozmunoz-1@tudelft.nl (F.A.M.); L.C.CastroHeredia@tudelft.nl (L.C.C.-H.)

\* Correspondence: A.RodrigoMor@tudelft.nl

The authors wish to make the following erratum to this paper [1]: the summation symbol in the Equations (11) and (12) should be a product symbol.

The corrected Equations (11) and (12) appear below:

$$H(s) = \frac{U(s)}{I(s)} = \frac{\alpha \cdot s \cdot \prod_{i=1}^{i=m} (s + z_i)}{\prod_{j=1}^{j=n} (s + p_j)} \quad (11)$$

$$\frac{U(s)}{s^2} = I(s) \frac{\alpha \cdot \prod_{i=1}^{i=m} (s + z_i)}{s \cdot \prod_{j=1}^{j=n} (s + p_j)} \quad (12)$$



**Citation:** Rodrigo-Mor, A.; Muñoz, F.A.; Castro-Heredia, L.C. Erratum: Rodrigo-Mor et al. Principles of Charge Estimation Methods Using High-Frequency Current Transformer Sensors in Partial Discharge Measurements. *Sensors* 2020, 20, 2520. *Sensors* 2021, 21, 6010. <https://doi.org/10.3390/s21186010>

Received: 26 July 2021

Accepted: 16 August 2021

Published: 8 September 2021

**Publisher's Note:** MDPI stays neutral with regard to jurisdictional claims in published maps and institutional affiliations.



**Copyright:** © 2021 by the authors. Licensee MDPI, Basel, Switzerland. This article is an open access article distributed under the terms and conditions of the Creative Commons Attribution (CC BY) license (<https://creativecommons.org/licenses/by/4.0/>).

The authors apologize for any inconvenience caused and state that the scientific conclusions are unaffected. The original article has been updated.

**Conflicts of Interest:** The author declares no conflict of interest.

## Reference

1. Rodrigo-Mor, A.; Muñoz, F.A.; Castro-Heredia, L.C. Principles of Charge Estimation Methods Using High-Frequency Current Transformer Sensors in Partial Discharge Measurements. *Sensors* 2020, 20, 2520. [[CrossRef](#)] [[PubMed](#)]